

Fairfield Public Schools
Fairfield, CT 06825

TO: Dr. David Title and Members of the Board of Education

FROM: Salvatore Morabito

DATE: September 24, 2013

RE: Osborn Hill Follow up Testing Results

This letter is to notify you that the Fairfield Public School District has received the results of the follow-up testing for Polychlorinated Biphenyl (PCB) at Osborn Hill School conducted on September 17, 2013. This testing consisted of air samples taken in Library Media Center, Library Media Center Office and the custodian storage room which previously tested above the EPA recommended limits in the last round of quarterly tests.

I am happy to report that all these follow up air samples documented levels below the USEPA recommended limits. Moving forward the additional engineering controls (negative air ventilation and additional containment barriers) recently installed in the Gymnasium will be inspected to ensure that these engineering controls are intact and are effective.

The analytical results that were attached to the AMC Report will be posted on the Fairfield Public Schools' website. The Central Office Administration and the Osborn Hill School Principal will keep PCB test reports on file per State regulations.

If you have any questions or concerns regarding the specialized cleaning or the PCB testing, please feel free to contact me at (203) 255-7363.

Thank you.

c: Meg Brown
Central Office Administration
Sands Cleary



ENVIRONMENTAL, LLC

September 23, 2013

Mr. Tom Cullen
Fairfield Board of Education
501 Kings Highway East
Fairfield, CT 06824

RE: Follow-Up PCB Operations and Maintenance Air Sampling Report for
Osborn Hill Elementary School

Dear Mr. Cullen:

INTRODUCTION

AMC Environmental performed follow-up PCB Air testing at Osborn Hill Elementary School located at 760 Stillson Road in Fairfield, CT on September 17, 2013 after elevated levels of PCBs were found in the August 21, 2013 sampling (see Report Dated September 5, 2013). The inspection included PCB air sampling in the Library, Library Office and Custodian Storage Closet/Office.

SAMPLING

PCB Air Sampling

PCB airborne sampling was conducted in four (4) areas of the school in accordance with the PCB Operations and Maintenance Plan. The areas sampled during the follow-up sampling were: Library (center), Library (near circulation desk), Library Office and the Custodial Office/Storage Closet.

The airborne samples were analyzed using EPA Method TO-10A for PCB Homolog Analysis and were submitted to Con-Test Analytical Laboratories in East Longmeadow, MA.

RESULTS

PCB Air Samples

A total of four (4) PCB airborne samples were obtained from the above mentioned areas at Osborn Hill Elementary School. All samples documented concentrations below the EPA recommended 300 ng/m³ threshold for children over the age of six. A more conservative threshold of 100 ng/m³ is the EPA recommended limit for

AMC
Environmental,
LLC

Phone:

203.378.5020

Fax:

203.375.7344

Email:

amc@amcenviro.com

P.O. Box 423
Stratford, CT 06615

kindergarten areas (<6 years old) within the school. Based on the sample results, the air samples collected in the Library, Library Office and the Custodial Office/Storage Closet all document acceptable levels of PCB in the air (see Analytical Results). Table 1 documents the location and sample results for PCB air samples obtained.

Table 1 – PCB Air Samples

Sample Number	Location	Results ng/m³
P-Air917-01	Library-center	210
P-Air917-02	Library-near circulation desk	280
P-Air917-03	Library Office	270
P-Air917-04	Custodial Office/Storage Closet	270

Conclusion

The follow-up testing documented acceptable results within the Library, Library Office and the Custodial Office/Storage Closet. The indoor PCB in air levels are satisfactory within the areas tested during this follow-up testing. All air samples obtained document PCB levels below the 300 ng/m³ threshold for children ages 6 to 12 years old. Please note unlike classrooms, children do not typically spend a significant amount of time in the library, library office or custodial office/storage closet, therefore levels below 300ng/m³ are still considered to be acceptable. EPA's recommended levels are based on a 6.5 hour school day for children over 3 years old. Please see air sample results in the table below. We are scheduled to do our next round of quarterly testing in November. As a reminder no activities or renovations that may potentially disturb PCBs shall be conducted without consulting with the PCB Coordinator or Designee. Please keep this follow-up report with the original August quarterly testing report. If you have any questions please do not hesitate to call.

Very truly,



Jason Pringle
Principal

LABORATORY RESULTS

September 20, 2013

Sandy Owen
AMC Environmental, LLC
PO Box 423
Stratford, CT 06615

Project Location: Osborn School
Client Job Number:
Project Number: [none]
Laboratory Work Order Number: 13I0600

Enclosed are results of analyses for samples received by the laboratory on September 18, 2013. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Lisa Worthington", is displayed on a light gray rectangular background.

Lisa A. Worthington
Project Manager

AMC Environmental, LLC
PO Box 423
Stratford, CT 06615
ATTN: Sandy Owen

REPORT DATE: 9/20/2013

PURCHASE ORDER NUMBER:

PROJECT NUMBER: [none]

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 1310600

The results of analyses performed on the following samples submitted to the CON-TEST Analytical Laboratory are found in this report.

PROJECT LOCATION: Osborn School

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
P-Air917 01	1310600-01	Air	Library-Center	TO-10A/EPA 680 Modified	
P-Air917 02	1310600-02	Air	Library-Near Circ. Desk	TO-10A/EPA 680 Modified	
P-Air917 03	1310600-03	Air	Library-Office	TO-10A/EPA 680 Modified	
P-Air917 04	1310600-04	Air	Custodian's Office	TO-10A/EPA 680 Modified	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Con-Test Analytical Laboratory for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.

A handwritten signature in black ink, appearing to read "M. Erickson", is displayed on a light gray rectangular background.

Michael A. Erickson
Laboratory Director

ANALYTICAL RESULTS

Project Location: Osborn School

Date Received: 9/18/2013

Field Sample #: P-Air917 01

Sample ID: 1310600-01

Sample Matrix: Air

Sampled: 9/17/2013 19:15

Sample Description/Location: Library-Center

Sub Description/Location:

Work Order: 1310600

Flow Controller ID:

Sample Type:

Air Volume L: 1800

TO-10A/EPA 680 Modified

Analyte	Total µg		Flag/Qual	ug/m3		Dilution	Date/Time		Analyst
	Results	RL		Results	RL		Analyzed		
Monochlorobiphenyls	ND	0.0010		ND	0.00056	1	9/19/13 17:40	CJM	
Dichlorobiphenyls	0.0039	0.0010		0.0022	0.00056	1	9/19/13 17:40	CJM	
Trichlorobiphenyls	0.0084	0.0010		0.0047	0.00056	1	9/19/13 17:40	CJM	
Tetrachlorobiphenyls	0.15	0.0020		0.085	0.0011	1	9/19/13 17:40	CJM	
Pentachlorobiphenyls	0.28	0.0020		0.16	0.0011	1	9/19/13 17:40	CJM	
Hexachlorobiphenyls	0.044	0.0020		0.025	0.0011	1	9/19/13 17:40	CJM	
Heptachlorobiphenyls	ND	0.0030		ND	0.0017	1	9/19/13 17:40	CJM	
Octachlorobiphenyls	ND	0.0030		ND	0.0017	1	9/19/13 17:40	CJM	
Nonachlorobiphenyls	ND	0.0050		ND	0.0028	1	9/19/13 17:40	CJM	
Decachlorobiphenyl	ND	0.0050		ND	0.0028	1	9/19/13 17:40	CJM	
Total Polychlorinated biphenyls	0.49			0.27		1	9/19/13 17:40	CJM	

Surrogates	% Recovery	% REC Limits	
Tetrachloro-m-xylene	78.5	50-125	9/19/13 17:40

ANALYTICAL RESULTS

Project Location: Osborn School

Date Received: 9/18/2013

Field Sample #: P-Air917 02

Sample ID: 1310600-02

Sample Matrix: Air

Sampled: 9/17/2013 19:15

Sample Description/Location: Library-Near Circ. Desk

Sub Description/Location:

Work Order: 1310600

Flow Controller ID:

Sample Type:

Air Volume L: 1800

TO-10A/EPA 680 Modified

Analyte	Total µg		Flag/Qual	ug/m3		Dilution	Date/Time		Analyst
	Results	RL		Results	RL		Analyzed		
Monochlorobiphenyls	ND	0.0010		ND	0.00056	1	9/19/13 18:09	CJM	
Dichlorobiphenyls	0.0034	0.0010		0.0019	0.00056	1	9/19/13 18:09	CJM	
Trichlorobiphenyls	0.0067	0.0010		0.0037	0.00056	1	9/19/13 18:09	CJM	
Tetrachlorobiphenyls	0.15	0.0020		0.082	0.0011	1	9/19/13 18:09	CJM	
Pentachlorobiphenyls	0.28	0.0020		0.16	0.0011	1	9/19/13 18:09	CJM	
Hexachlorobiphenyls	0.043	0.0020		0.024	0.0011	1	9/19/13 18:09	CJM	
Heptachlorobiphenyls	ND	0.0030		ND	0.0017	1	9/19/13 18:09	CJM	
Octachlorobiphenyls	ND	0.0030		ND	0.0017	1	9/19/13 18:09	CJM	
Nonachlorobiphenyls	ND	0.0050		ND	0.0028	1	9/19/13 18:09	CJM	
Decachlorobiphenyl	ND	0.0050		ND	0.0028	1	9/19/13 18:09	CJM	
Total Polychlorinated biphenyls	0.48			0.27		1	9/19/13 18:09	CJM	

Surrogates	% Recovery	% REC Limits	
Tetrachloro-m-xylene	79.0	50-125	9/19/13 18:09

ANALYTICAL RESULTS

Project Location: Osborn School

Date Received: 9/18/2013

Field Sample #: P-Air917 03

Sample ID: 1310600-03

Sample Matrix: Air

Sampled: 9/17/2013 19:15

Sample Description/Location: Library-Office

Sub Description/Location:

Work Order: 1310600

Flow Controller ID:

Sample Type:

Air Volume L: 1800

TO-10A/EPA 680 Modified

Analyte	Total µg		Flag/Qual	ug/m3		Dilution	Date/Time		Analyst
	Results	RL		Results	RL		Analyzed		
Monochlorobiphenyls	ND	0.0010		ND	0.00056	1	9/19/13 18:39	CJM	
Dichlorobiphenyls	0.0038	0.0010		0.0021	0.00056	1	9/19/13 18:39	CJM	
Trichlorobiphenyls	0.0096	0.0010		0.0053	0.00056	1	9/19/13 18:39	CJM	
Tetrachlorobiphenyls	0.16	0.0020		0.087	0.0011	1	9/19/13 18:39	CJM	
Pentachlorobiphenyls	0.28	0.0020		0.16	0.0011	1	9/19/13 18:39	CJM	
Hexachlorobiphenyls	0.043	0.0020		0.024	0.0011	1	9/19/13 18:39	CJM	
Heptachlorobiphenyls	ND	0.0030		ND	0.0017	1	9/19/13 18:39	CJM	
Octachlorobiphenyls	ND	0.0030		ND	0.0017	1	9/19/13 18:39	CJM	
Nonachlorobiphenyls	ND	0.0050		ND	0.0028	1	9/19/13 18:39	CJM	
Decachlorobiphenyl	ND	0.0050		ND	0.0028	1	9/19/13 18:39	CJM	
Total Polychlorinated biphenyls	0.50			0.28		1	9/19/13 18:39	CJM	

Surrogates	% Recovery	% REC Limits	
Tetrachloro-m-xylene	77.9	50-125	9/19/13 18:39

ANALYTICAL RESULTS

Project Location: Osborn School

Date Received: 9/18/2013

Field Sample #: P-Air917 04

Sample ID: 1310600-04

Sample Matrix: Air

Sampled: 9/17/2013 19:21

Sample Description/Location: Custodian's Office

Sub Description/Location:

Work Order: 1310600

Flow Controller ID:

Sample Type:

Air Volume L: 1825

TO-10A/EPA 680 Modified

Analyte	Total µg		Flag/Qual	ug/m3		Dilution	Date/Time		Analyst
	Results	RL		Results	RL		Analyzed		
Monochlorobiphenyls	ND	0.0010		ND	0.00055	1	9/19/13 19:08	CJM	
Dichlorobiphenyls	ND	0.0010		ND	0.00055	1	9/19/13 19:08	CJM	
Trichlorobiphenyls	0.010	0.0010		0.0056	0.00055	1	9/19/13 19:08	CJM	
Tetrachlorobiphenyls	0.12	0.0020		0.065	0.0011	1	9/19/13 19:08	CJM	
Pentachlorobiphenyls	0.22	0.0020		0.12	0.0011	1	9/19/13 19:08	CJM	
Hexachlorobiphenyls	0.041	0.0020		0.022	0.0011	1	9/19/13 19:08	CJM	
Heptachlorobiphenyls	ND	0.0030		ND	0.0016	1	9/19/13 19:08	CJM	
Octachlorobiphenyls	ND	0.0030		ND	0.0016	1	9/19/13 19:08	CJM	
Nonachlorobiphenyls	ND	0.0050		ND	0.0027	1	9/19/13 19:08	CJM	
Decachlorobiphenyl	ND	0.0050		ND	0.0027	1	9/19/13 19:08	CJM	
Total Polychlorinated biphenyls	0.39			0.21		1	9/19/13 19:08	CJM	

Surrogates	% Recovery	% REC Limits	
Tetrachloro-m-xylene	60.7	50-125	9/19/13 19:08

Sample Extraction Data

Prep Method: SW-846 3540C-TO-10A/EPA 680 Modified

Lab Number [Field ID]	Batch	Initial [Cartridge	Final [mL]	Date
13I0600-01 [P-Air917 01]	B081101	1.00	1.00	09/18/13
13I0600-02 [P-Air917 02]	B081101	1.00	1.00	09/18/13
13I0600-03 [P-Air917 03]	B081101	1.00	1.00	09/18/13
13I0600-04 [P-Air917 04]	B081101	1.00	1.00	09/18/13

QUALITY CONTROL
PCB Homologues by GC/MS with Soxhlet Extraction - Quality Control

Analyte	Total µg		ug/m3		Spike Level	Source	%REC	%REC	RPD	RPD	Flag/Qual
	Results	RL	Results	RL	Total µg	Result	%REC	Limits	RPD	Limit	

Batch B081101 - SW-846 3540C
Blank (B081101-BLK2)

Prepared: 09/18/13 Analyzed: 09/19/13

Monochlorobiphenyls	ND	0.0010
Dichlorobiphenyls	ND	0.0010
Trichlorobiphenyls	ND	0.0010
Tetrachlorobiphenyls	ND	0.0020
Pentachlorobiphenyls	ND	0.0020
Hexachlorobiphenyls	ND	0.0020
Heptachlorobiphenyls	ND	0.0030
Octachlorobiphenyls	ND	0.0030
Nonachlorobiphenyls	ND	0.0050
Decachlorobiphenyl	ND	0.0050
Total Polychlorinated biphenyls	0.0	

Surrogate: Tetrachloro-m-xylene 0.167 0.200 83.6 50-125

LCS (B081101-BS1)

Prepared: 09/18/13 Analyzed: 09/19/13

Monochlorobiphenyls	0.18	0.0010	0.200	90.7	40-140
Dichlorobiphenyls	0.19	0.0010	0.200	97.4	40-140
Trichlorobiphenyls	0.19	0.0010	0.200	96.5	40-140
Tetrachlorobiphenyls	0.40	0.0020	0.400	100	40-140
Pentachlorobiphenyls	0.39	0.0020	0.400	96.3	40-140
Hexachlorobiphenyls	0.37	0.0020	0.400	93.2	40-140
Heptachlorobiphenyls	0.57	0.0030	0.600	95.0	40-140
Octachlorobiphenyls	0.52	0.0030	0.600	86.6	40-140
Nonachlorobiphenyls	0.88	0.0050	1.00	88.0	40-140
Decachlorobiphenyl	0.84	0.0050	1.00	83.6	40-140

Surrogate: Tetrachloro-m-xylene 0.193 0.200 96.4 50-125

LCS Dup (B081101-BSD1)

Prepared: 09/18/13 Analyzed: 09/19/13

Monochlorobiphenyls	0.13	0.0010	0.200	64.9	40-140	33.2	50
Dichlorobiphenyls	0.14	0.0010	0.200	69.7	40-140	33.1	50
Trichlorobiphenyls	0.14	0.0010	0.200	71.0	40-140	30.5	50
Tetrachlorobiphenyls	0.29	0.0020	0.400	71.9	40-140	33.1	50
Pentachlorobiphenyls	0.32	0.0020	0.400	81.1	40-140	17.1	50
Hexachlorobiphenyls	0.31	0.0020	0.400	77.0	40-140	19.0	50
Heptachlorobiphenyls	0.48	0.0030	0.600	79.4	40-140	17.8	50
Octachlorobiphenyls	0.47	0.0030	0.600	77.8	40-140	10.7	50
Nonachlorobiphenyls	0.82	0.0050	1.00	82.4	40-140	6.64	50
Decachlorobiphenyl	0.82	0.0050	1.00	82.5	40-140	1.33	50

Surrogate: Tetrachloro-m-xylene 0.129 0.200 64.4 50-125

FLAG/QUALIFIER SUMMARY

- * QC result is outside of established limits.
- † Wide recovery limits established for difficult compound.
- ‡ Wide RPD limits established for difficult compound.
- # Data exceeded client recommended or regulatory level

Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.

No results have been blank subtracted unless specified in the case narrative section.

CERTIFICATIONS

Certified Analyses included in this Report

Analyte	Certifications
---------	----------------

TO-10A/EPA 680 Modified in Air

Total Polychlorinated biphenyls AIHA

The CON-TEST Environmental Laboratory operates under the following certifications and accreditations:

Code	Description	Number	Expires
AIHA	AIHA-LAP, LLC	100033	02/1/2014
MA	Massachusetts DEP	M-MA100	06/30/2014
CT	Connecticut Department of Public Health	PH-0567	09/30/2013
NY	New York State Department of Health	10899 NELAP	04/1/2014
NH-S	New Hampshire Environmental Lab	2516 NELAP	02/5/2014
RI	Rhode Island Department of Health	LAO00112	12/30/2013
NC	North Carolina Div. of Water Quality	652	12/31/2013
NJ	New Jersey DEP	MA007 NELAP	06/30/2014
FL	Florida Department of Health	E871027 NELAP	06/30/2014
VT	Vermont Department of Health Lead Laboratory	LL015036	07/30/2014
WA	State of Washington Department of Ecology	C2065	02/23/2014
ME	State of Maine	2011028	06/9/2015
VA	Commonwealth of Virginia	460217	12/14/2013
NH-P	New Hampshire Environmental Lab	2557 NELAP	09/6/2014



Phone: 413-525-2332
Fax: 413-525-6405
Email: info@contestlabs.com
www.contestlabs.com

AIR SAMPLE CHAIN OF CUSTODY

RECORD

1310600

39 SPRUCE ST
EAST LONGMEADOW, MA 01028

Page 1 of 1

Company Name:

AMC Environmental, LLC

Address:

P.O. Box 423

Attention:

State's, CT 06605

Project Location:

Osborn School

Sampled By:

Jason Pringle

Proposal Provided? (For Billing purposes)

☐ yes ☐ no

proposal date

Telephone: (203) _____
Project # _____
Client PO # _____

DATA DELIVERY (check one):
☒ FAX ☐ EMAIL ☐ WEBSITE CLIENT

Fax #:

Email:

Format: ☐ EXCEL ☐ PDF ☐ GIS KEY ☐ OTHER

Date Sampled

ONLY USE WHEN USING PUMPS

Field ID	Sample Description	Media	Lab #	Date Time	Stop Time	Total Minutes Sampled	Flow Rate M ³ /Min. or L / Min.	Volume Liters or M ³	Matrix Code*
----------	--------------------	-------	-------	-----------	-----------	-----------------------	--	---------------------------------	--------------

0-Air 0101 Library - Center 01 9/17 13:15 19:15 360 5.0 1800.0

2-Air 0102 Library - cit. BSK 02 9/17 13:15 19:15 360 5.0 1800.0

0-Air 0103 Library - Office 03 9/17 13:15 19:15 360 5.0 1800.0

0-Air 0104 Custodian's Office 04 9/17 13:16 19:21 365 5.0 1825.0

Laboratory Comments:

CLIENT COMMENTS:

Requested by (signature)	Date/Time:
Relinquished by (signature)	Date/Time:
Received by (signature)	Date/Time:

Turnaround **

☐ 7-Day

☐ 10-Day

☐ Other

RUSH *

☐ 24-Hr ☒ 48-Hr

☐ 72-Hr ☐ 14-Day

Special Requirements

*Matrix Code:

**Media Codes:

ANALYSIS REQUESTED

Hg

Please fill out completely, sign, date and retain the yellow copy for your record

Summa canisters are flow controllers must be returned within 14 days of receipt or rental fee will apply.

Summa canisters will be retained for a minimum of 14 days after sampling date prior to cleaning.

Summa Canister ID

Flow Control ID



Page 1 of 2

39 Spruce St.
East Longmeadow, MA.
01028
P: 413-525-2332
F: 413-525-6405

AIR Only Receipt Checklist

CLIENT NAME: AMC Environmental RECEIVED BY: RLJ DATE: 9/18/13

1) Was the chain(s) of custody relinquished and signed? ☒ Yes ☐ No

2) Does the chain agree with the samples? ☒ Yes ☐ No

If not, explain:

3) Are all the samples in good condition? ☒ Yes ☐ No

If not, explain:

4) Are there any samples "On Hold"? ☐ Yes ☒ No

Stored where:

5) Are there any ~~RUSH~~ or SHORT HOLDING TIME samples? ☒ Yes ☐ No

Who was notified _____ Date _____ Time _____

6) Location where samples are stored:

19

Permission to subcontract samples? Yes No
(Walk-in clients only) if not already approved
Client Signature: _____

7) Temperature °C by Temp blank _____ Temperature °C by Temp gun 39.9°C

Containers received at Con-Test

	# of Containers	Types (Size, Duration)
Summa Cans (TO-14/TO-15/APH)		
Tedlar Bags		
TO-17 Tubes		
Regulators		
Restrictors		
Hg/Hopcalite Tube (NIOSH 6009)		
(TO-4A/ <u>TO-10A</u> /TO-13) PUFs	4	low volume
PCB Florisil Tubes (NIOSH 5503)		
Air cassette		
PM 2.5/PM 10		
TO-11A Cartridges		
Other		

Unused Summas/PUF Media:

Unused Regulators:

1) Was all media (used & unused) checked into the WASP?

2) Were all returned summa cans, Restrictors & Regulators and PUF's documented as returned in the Air Lab Inbound/Outbound Excel Spreadsheet?

Laboratory Comments:

082713-01 082713-03
082713-02 082713-04

Login Sample Receipt Checklist**(Rejection Criteria Listing - Using Sample Acceptance Policy)****Any False statement will be brought to the attention of Client**

<u>Question</u>	<u>Answer (True/False)</u>		<u>Comment</u>
	<u>T/F/NA</u>		
1) The cooler's custody seal, if present, is intact.	T		
2) The cooler or samples do not appear to have been compromised or tampered with.	T		
3) Samples were received on ice.	T		
4) Cooler Temperature is acceptable.	T		
5) Cooler Temperature is recorded.	T		
6) COC is filled out in ink and legible.	T		
7) COC is filled out with all pertinent information.	T		
8) Field Sampler's name present on COC.	T		
9) There are no discrepancies between the sample IDs on the container and the COC.	T		
10) Samples are received within Holding Time.	T		
11) Sample containers have legible labels.	T		
12) Containers are not broken or leaking.	T		
13) Air Cassettes are not broken/open.	NA		
14) Sample collection date/times are provided.	T		
15) Appropriate sample containers are used.	T		
16) Proper collection media used.	T		
17) No headspace sample bottles are completely filled.	NA		
18) There is sufficient volume for all requested analyses, including any requested MS/MSDs.	NA		
19) Trip blanks provided if applicable.	NA		
20) VOA sample vials do not have head space or bubble is <6mm (1/4") in diameter.	NA		
21) Samples do not require splitting or compositing.	T		

Doc #278 Rev. 3 August 2013

Who notified of False statements?

Date/Time:

Log-In Technician Initials:

Date/Time:

RLF 9/18/13 1700