



STATE OF CONNECTICUT
 DEPARTMENT OF PUBLIC HEALTH
 RADON PROGRAM
SCHOOL RADON RE-EVALUATION REPORT FORM

Dec 2010

The following form must be submitted to the Connecticut Department of Public Health Radon Program within ten (10) business days of providing a final written report of radon measurement activities to school personnel. Submit this signed form by mail OR fax to the Radon Program at the address listed below:

CT Department of Public Health Radon Program
 410 Capitol Avenue, MS #51 RAD
 Hartford, CT 06134-0308
 OR
 Fax: 860-509-7378

Name of School: Riverfield Elementary School

Address: 1625 Mill Plain Road
 (Street, town, zip code) Fairfield, CT 06824

Measurement Company Name: HYGENIX, Inc.

Please provide the following summary information:

Testing Dates: 01/31 - 02/03/2011

Total # of Rooms Tested: 13

Total # of Rooms Requiring Re-Testing: —

Total # of Rooms Where Average Results were at or above 4.0 pCi/L: —

Radon measurement activities were performed at the location above in accordance with United States Environmental Protection Agency protocols and the Connecticut Department of Public Health Radon Program's *School Radon Testing Guidance*.

Ted Tio / 6550041
 Measurement Professional / NEHA/NRSB #

[Signature]
 Signature 02/09/11
 Date

DAVE FRYER
 School Designee / Title

[Signature]
 Signature 2/15/11
 Date



Phone: (860) 509-7367
 Telephone Device for the Deaf (860) 509-7191
 450 Capitol Avenue - MS # 51RAD
 P.O. Box 340308 Hartford, CT 06134
 An Equal Opportunity Employer



49 Woodside Street Stamford, CT 06902

Fairfield Public Schools
Attn. Dave Fryer
501 Kings Highway East, Suite 210
Fairfield, CT 06825

February 16, 2011

Re: Radon Re-evaluation
Riverfield Elementary School
Fairfield, CT

Dear Mr. Fryer:


Enclosed with this letter are the results of radon testing conducted at Riverfield Elementary School. The testing was conducted in accordance with Connecticut Department of Public Health radon re-evaluation protocols. Listed below is a summary of the retesting results.

Test Date	Location	Results
01/31/11 - 02/03/11	Classroom 29	<0.3pCi/L
01/31/11 - 02/03/11	Classroom 30	<0.3pCi/L
01/31/11 - 02/03/11	Classroom 31	<0.3pCi/L
01/31/11 - 02/03/11	Classroom 15	0.6pCi/L
01/31/11 - 02/03/11	Classroom 21	0.9pCi/L
01/31/11 - 02/03/11	Classroom 26	0.6pCi/L
01/31/11 - 02/03/11	Classroom 03	<0.3pCi/L
01/31/11 - 02/03/11	Classroom 06	0.6pCi/L
01/31/11 - 02/03/11	Gymnasium	1.2pCi/L
01/31/11 - 02/03/11	Gymnasium	1.1pCi/L
01/31/11 - 02/03/11	Gymnasium	1.2pCi/L
01/31/11 - 02/03/11	Gymnasium Office	0.6pCi/L
01/31/11 - 02/03/11	Media Center	<0.3pCi/L
01/31/11 - 02/03/11	Media Center	<0.3pCi/L
01/31/11 - 02/03/11	Media Center	<0.3pCi/L
01/31/11 - 02/03/11	Music 32	<0.3pCi/L
01/31/11 - 02/03/11	Music 33	<0.3pCi/L
01/31/11 - 02/03/11	QA/QC Blank	<0.3pCi/L

As reported on the attached laboratory report, none of the test kits deployed during this round of testing returned results that exceeded the Environmental Protection Agency action level of 4 pCi/L.

If you have questions or would like to discuss the radon testing, please call me at 203-324-2222.

Sincerely,



Ted Tio, MS, CIEC
Hygenix, Inc.

February 9, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

RFES

MAIN

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4417909	CR 29	2011-01-31 @ 2:00 pm	2011-02-03 @ 4:00 pm	< 0.3	2011-02-08
4417906	CR 30	2011-01-31 @ 2:00 pm	2011-02-03 @ 4:00 pm	< 0.3	2011-02-08
4417905	CR 31	2011-01-31 @ 2:00 pm	2011-02-03 @ 4:00 pm	< 0.3	2011-02-08
4417911	CR15	2011-01-31 @ 2:00 pm	2011-02-03 @ 4:00 pm	0.6	2011-02-08
4511975	CR21	2011-01-31 @ 2:00 pm	2011-02-03 @ 4:00 pm	0.9	2011-02-08
4511978	CR26	2011-01-31 @ 2:00 pm	2011-02-03 @ 4:00 pm	0.6	2011-02-08
4417902	CR3	2011-01-31 @ 2:00 pm	2011-02-03 @ 4:00 pm	< 0.3	2011-02-08
4417904	CR6	2011-01-31 @ 2:00 pm	2011-02-03 @ 4:00 pm	0.6	2011-02-08
4511993	GYM	2011-01-31 @ 2:00 pm	2011-02-03 @ 4:00 pm	1.2	2011-02-08
4503398	GYM	2011-01-31 @ 2:00 pm	2011-02-03 @ 4:00 pm	1.1	2011-02-08
4503362	GYM	2011-01-31 @ 2:00 pm	2011-02-03 @ 4:00 pm	1.2	2011-02-08
4511977	GYM OFF	2011-01-31 @ 2:00 pm	2011-02-03 @ 4:00 pm	0.6	2011-02-08
4417908	MEDIA CTR	2011-01-31 @ 2:00 pm	2011-02-03 @ 4:00 pm	< 0.3	2011-02-08
4417907	MEDIA CTR	2011-01-31 @ 2:00 pm	2011-02-03 @ 4:00 pm	< 0.3	2011-02-08
4417903	MEDIA CTR	2011-01-31 @ 2:00 pm	2011-02-03 @ 4:00 pm	< 0.3	2011-02-08
4511986	MUSIC 32	2011-01-31 @ 2:00 pm	2011-02-03 @ 4:00 pm	< 0.3	2011-02-08
4511981	MUSIC 33	2011-01-31 @ 2:00 pm	2011-02-03 @ 4:00 pm	< 0.3	2011-02-08
4417912	RFESB	2011-01-31 @ 2:00 pm	2011-02-03 @ 4:00 pm	< 0.3	2011-02-08
